NOTICE ABOUT YOUR DRINKING WATER Arsenic Maximum Contaminant Level (MCL) Exceedance

Public Water System Name:FREEDOM HILL COOP PWS ID:1403030				
monitoring are an indicate The Running Annual Ave	nitor your drinking water f ator of whether or not you erage (RAA) calculation re Irinking water RAA calcula	ur drinking water m presents the avera	eets health standar ge of all sample resu	ds. Ilts collected within a
Contaminant and MCL	Detected Level	Date Sampled	Running Annual Average	Compliance Period
Arsenic 0.0050 mg/L	0.0339 mg/L, 0.019 mg/L, 0.0147 mg/L, 0.0251 mg/L, 0.0032 mg/L	January 3, 2023	0.0191 mg/L	Quarter 1, 2023
This is not an emergency. If it had been you would have been notified immediately. Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer. What should I do? It is not necessary to use alternate water; however, if you have specific health concerns, please contact your health care professional. General health-related questions may be directed to the EPA Safe Drinking Water Hotline at 1-800-426-4791.				
Steps being taken to correct the situation:WE ARE CURRENTLY IN THE PROCESS OF PREPARING TO INSTALL THE STATE APPROVED UPDATED ARSENIC TREATMENT. Expected Resolution Date:JUNE 30, 2023				
Contact Name: _Craig McGraw Company:Aquamen Water Solutions				
Address: _668 1st New Hampshire Tpk, Northwood, NH 03261_Telephone Number: _603-942-6138				

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example; people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.